

# 2008 Annual Drinking Water Quality Report

## HARRIS COUNTY WCID No. 119

*Yes, your water  
is safe to drink*



### OUR WATER MEETS ALL FEDERAL (EPA) AND STATE REQUIREMENTS

The Texas Commission on Environmental Quality (TCEQ) assessed our system, Harris County WCID No. 119 (WCID No. 119), and determined that our water is safe to drink. The analysis was made by using the data in the tables in this report which uses testing results from 2004 through 2008. Because our water meets all state and federal drinking water health standards for the sampling period, there may not be any health based benefits to purchasing bottled water or point of use devices.

WCID No. 119 system identification number is 101-0509. We hope this information helps you become more knowledgeable about what's in your drinking water.

**En Español – Este reporte incluye informacion importante sobre el agua para tomar. Si tiene preguntas o discusiones sobre este reporte en espanol, favor de llamar al tel. 281.376.8802 par hablar con una persona bilingue en espanol.**

**TABLE INFORMATION** The tables contain chemical constituents which have been found in your drinking water. The TCEQ and the Environmental Protection Agency (EPA) require water systems to test up to 97 constituents. Only six regulated constituents were detected in WCID No. 119's water, and these were well below the maximum contaminant level allowed in drinking water. The agencies do not require some contaminants to be monitored annually because their concentrations are not expected to vary. This report states the results of the most current water testing from 2004 through 2008.



REGULATED INORGANICS									
Year Tested	Contaminant Detected	Unit of Measure	Average Level *	Minimum Level *	Maximum Level *	Allowed (EPA's MCL)	MCLG	Meets Standards	Possible source of Contaminant
2006-08	Arsenic <sup>‡</sup>	ppb	3.200	0.000	6.40	10.0**	0.0	yes	Erosion of natural deposits
** The arsenic MCL of 10 was made effective January 23, 2006. Prior to January the MCL was 50 ppb, with no MCLG.									
2005-08	Barium	ppm	0.176	0.053	0.299	2.0	2.0	yes	Erosion of natural deposits
2008	Fluoride <sup>‡‡</sup>	ppm	1.350	0.250	2.490	4.0	4.0	yes	Erosion of natural deposits
2008	Nitrate	ppm	0.010	0.000	0.020	10.0	10.0	yes	Erosion of natural deposits

**‡ ARSENIC:** While your drinking water meets EPA's standards for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the cost of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

### ‡ #FLUORIDE PUBLIC NOTIFICATION

This is an alert about your drinking water and a cosmetic dental problem that might affect children under nine years of age. At low levels, fluoride can help prevent cavities, but children drinking water containing more than 2 ppm of fluoride may develop cosmetic discoloration of their permanent teeth (dental fluorosis). The drinking water provided by WCID 119 has a fluoride concentration of 0.25 to 2.79 ppm. WCID 119's Public Water System ID is No. 101-0509.

Dental fluorosis, in its moderate or severe forms, may result in a brown staining and/or pitting of the permanent teeth. This problem occurs only in developing teeth, before they erupt from the gums. Children under nine should be provided with alternative sources of drinking water or water that has been treated to remove the fluoride to avoid the possibility of staining and pitting of their permanent teeth. You may also want to contact your dentist about proper use by young children of fluoride-containing products. Older children and adults may safely drink the water.

Drinking water containing more than 4.0 ppm of fluoride (the U.S. EPA's drinking water standard) can increase your risk of developing bone disease. Your drinking water does not contain more than 4.0 ppm of fluoride, but we're required to notify you when we discover that the fluoride levels in your drinking water exceed 2.0 ppm because of this cosmetic dental problem.

UNREGULATED CONTAMINANT						
Tested	Contaminant	Unit	Average *	Minimum *	Maximum *	Source of Contaminant
2008	Bromodichloromethane	ppb	2.50	2.50	2.50	The Unregulated contaminants listed are byproducts of the drinking water disinfection.
2008	Bromoform	ppb	8.70	8.70	8.70	
2008	Chloroform	ppb	0.90	0.90	0.90	
2008	Dibromochloromethane	ppb	7.00	7.00	7.00	

\* When there is only one sample, the average, minimum, and maximum will be the same number.

Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted.

### DEFINITIONS

**Contaminant:** The technical term for anything else in water except pure water is "contaminant." Technically, pure, fresh orange juice can be considered water which has been "contaminated" by the oil, orange pulp and flavorings in the orange which make it taste so good. Obviously, some contaminants aren't good and can actually be hazardous to your health at specific levels. Those are the ones that are tested and measured.

**Action Level:** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**MCL, Maximum Contaminant Level:** The highest level of a contaminant allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology. MCLs are set at very stringent levels.

**MCLG, Max. Contaminant Level Goal:** The level of a contaminant in drinking water below which there is no known or expected health risk. MCLGs allow for a margin of safety.

**MRDL, Max. Residual Disinfectant Level:** The highest level of disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**MRDLG, Max. Residual Disinfectant Level Goal:** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

**n/a:** not established at this time

**pCi/L:** PicoCuries per liter

**ppm - Part per million:** One part per million equals 1 teaspoon in 1,302 gallons, which is enough water to fill a typical bathtub over 40 times.

**ppb - Part per billion:** One part per billion equals 1 teaspoon in 1,302,000 gallons, which is enough water to fill a typical bathtub over 40,000 times.

## WHAT'S IN THE WATER

In order to ensure that tap water is safe to drink, the EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.



Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk.

More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline, 1.800.426.4791, or at the following web site: [www.epa.gov/safewater](http://www.epa.gov/safewater).

Bottled water information may be obtained at: [www.nrdc.org/water/drinking/bw/bwinx.asp](http://www.nrdc.org/water/drinking/bw/bwinx.asp).

### DISINFECTANT RESIDUALS

Year	Constituent	Unit	Average	Minimum	Maximum	MRDL	MRDLG	Possible Source of Contaminant
2008	Free Chlorine	ppm	1.61	1.00	2.60	4.0	4.0	Disinfectant used to control microbes

### DISINFECTANT BYPRODUCTS

Year	Constituent	Unit	Average*	Minimum*	Maximum*	MCL	Source
2005	Total Haloacetic Acids	ppb	1.60	0.00	3.20	60.0	Byproduct of drinking water disinfection
2005	Total Trihalomethanes	ppb	9.80	0.00	19.60	80.0	Byproduct of drinking water disinfection

Total Trihalomethanes and Haloacetic Acids represents four different constituents. The maximum is the sum of all four.

### LEAD AND COPPER – TESTED AT THE CUSTOMER'S TAP (SAMPLES WERE COLLECTED AT 20 HOMES)

Year Tested	Substance	Unit of Measure	90th Percentile	# of Homes Exceeding Action Level	Action Level	Possible Sources of Lead and Copper
2007	Lead	ppb	5.600	0 of 20	15.0	Corrosion of household plumbing systems;
2007	Copper	ppm	0.142	0 of 20	1.3	Erosion of natural deposits

**INFORMATION ON LEAD IN WATER** Infants and young children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing.



If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested.

You can reduce lead consumption by running your faucet for 30 seconds to 2 minutes before using the water for drinking or cooking. Additional information is available from the Safe Drinking Water Hotline at 1.800.426.4791.

**SECONDARY CONSTITUENTS** Many contaminants (such as calcium, sodium, or iron) which are often found in drinking water can cause taste, color, and odor problems. These constituents are called secondary contaminants and are regulated by the State of Texas, not EPA. The secondary constituents are not causes for health concerns. Therefore, secondaries are not required to be reported in this document, but they may greatly affect the appearance and taste of your water.

### SOURCE WATER ASSESSMENT

TCEQ completed an assessment of your source water and results indicate that some of our sources are susceptible to certain contaminants. The sampling requirements for your water system are based on this susceptibility and previous sample data. Any detections of these contaminants will be found in this Water Quality Report. For more information on source water assessments and protection efforts at our system, contact 281.376.8802.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals, and in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water before treatment include: microbes, inorganic contaminants, pesticides, herbicides, radioactive contaminants, and organic chemical contaminants.

### OUTSTANDING PERFORMANCE

WCID No. 119 has been awarded Outstanding Performance Certificates for no violations of the Safe Drinking Water Act bacteriological sampling rule from 2001-2007. The District continues with the same performance record to date.

### WHERE YOUR WATER COMES FROM

Your drinking water comes from three wells, here in the District. The wells draw water from the Chicot, Evangeline, and the Jasper Aquifers.

The District also has three interconnect valves with neighboring Charterwood MUD, Louetta North PUD (Colony Creek), HC MUD No. 367 (Gleannloch Farms), and North Harris County Regional Water Authority groundwater supply, all of which are governed by the same drinking water regulations.

### PUBLIC PARTICIPATION

WCID No. 119 meets at 5:30 p.m. in the District on the second Monday of each month at 9711 Landry, behind the fire station. Any last minute cancellations will be posted on the bulletin board at this location. Call 281.376.8802 for directions.

### HAVE QUESTIONS

If you would like more information about particular health risks or contaminants, you may call the EPA at 1.800.426.4791, or the Harris County Health Department at 713.439.6000. The District's Operator, Water District Management (WDM), may also be able to assist you with your questions, 281.376.8802.



**ADDITIONAL TESTING** Additional testing is done daily at the water plant and throughout the community at various locations to ensure that a safe level of disinfectant is in the system. Water samples are sent to an independent state approved laboratory to verify the absence of harmful bacteria. No such bacteria has been detected in this water system.

### HOW TO FIND LEAKS

Dripping, trickling faucets, showerheads and toilets can waste from 75 to several hundred gallons of water a week depending on the size of the leaks.



Worn-out washers are the main cause when faucets and showerheads leak. A new washer generally costs about 25 cents.

That trickling sound coming from the bathroom is probably a leaky toilet but keep in mind sometimes toilet leaks can be silent.

**TRY THIS:** Put a couple of drops of food coloring in the tank of the toilet and wait an hour or so. If water in the bowl turn color than the toilet is leaking. Most likely the flapper or flush valve needs to be replaced. Parts are inexpensive and easy to replace.

### SPECIAL NOTICE

**FOR THE ELDERLY, INFANTS, CANCER PATIENTS, PEOPLE WITH HIV/AIDS OR OTHER IMMUNE PROBLEMS:**

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS, those that are undergoing treatment with steroids, or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers.

EPA/Centers for Disease Control and Prevention (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline, 1.800.426.4791.